



Form J

(See Rule 36)

Report No-1199

Type of Sample: Legal

Dated:- 15.10.2024

I hereby, certify that I Neeraj Bala Board Analyst duly appointed under sub section (3) of section 53 of the Water (Prevention and Control of Pollution) Act 1974 (06 of 1974), received a sample on the 09th day of October, 2024, collected by Sh. Anil Kumar, Sc.B dated 08th day of October, 2024 of M/s Divya Waste Management Co. VPO- Shapur, Tehsil- Alewa, Distt. Jind for analysis.

Further certify that I have analyzed the above mentioned sample on 09th October-2024 to 15th -October-2024 and declare the result of analysis to be as follows:

Sr. No.	Parameter Name	Result	Result	Limit	Test Method
1.	Sample Code	2331	2332		
2.	Sample Collected from	Inlet of ETP	Outlet of ETP		
3.	Color	Blackish	Colourless	-	
4.	Odour	Bad	Odourless	-	
5.	pH value at 25°C	6.59	6.87	5.5-9.0	APHA4500-H+ (B)
6.	Biological Oxygen Demand (mg/l)	145.0	6.5	30	IS:3025(Part-44)
7.	Chemical Oxygen Demand (mg/l)	492.0	36.0	250	APHA 5220 (B)
8.	Total Suspended Solids mg/l	290.0	12.0	100	APHA 2540 (D)
9.	Oil and Grease (mg/l)	24.5	BDL(DL=2)	10	APHA 5520-B
10.	Conductivity at 25°C (µS/cm)	1462.0	1086.0	-	IS:3025(Part-14)

The Conditions of the seals, listening and container on receipt was as follows:

Container had its seal found intact and in order, slip on the container had the signature of the representative of the industry and the Board.

Signed this **15th day of October, 2024**

Haryana State Pollution Control Board Laboratory,
C-11, Sector-06, Panchkula, Haryana

To

The Member Secretary, HSPCB, Panchkula

CC to Regional Office: **Jind**. This test report relate only to the particular sample submitted for testing.

Neeraj Bala
Board Analyst

End of the Report