



# Envirochem Testing & Consultancy LLP

(Formerly known as Envirochem Testing Lab & Research Centre)

(GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M. : +91 90348 91129, 89501 75388

Email : envirochemtestinglab@gmail.com

Web. : www.etlrc.com

## TEST REPORT

Report No	ETL/PNP/57431	Report Date	18.03.2025	Doc No.	ETL/QF/7.8/01
Issue to: M/s Divya Waste Management Co. VPO Shahpur Distt. Jind		Party's Ref No: Nil  Work Order No: 40644  Period of Testing: 18.03.2025			
SAMPLE PARTICULARS					
1	Type of sample	: DG NOISE- (62.5 KVA)			
2	Date of sample measurement	: 18.03.2025			
3	Purpose of analysis	: Monitoring purpose			
4	Sample collected/ supplied by	: By Lab Representative			

## OBSERVATIONS

Sr. No.	Point of measurement	I	II	III	IV	V	VI
1.	Acoustic Enclosure (0.5 m away from DG)	71.3	70.5	71.1	73.1	69.3	71.4

## TEST RESULTS

Sr. No.	Point of measurement	Noise Level (dB)			Standard Limit (dB)
		Min.	Max.	Average	
1.	Acoustic Enclosure (0.5 m away from DG)	69.3	73.1	71.2	75

Remarks: Analysed Parameters meet the Standards Limits.

\*\*\*\*\*End Report\*\*\*\*\*

Verified By  
Chemist



Authorized By  
Neha Singh